

B-310 OFFICE (100 - 150 S.F.)

Wheelchair accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls floor to structure, STC 45 minimum.
- Door and frame, hollow metal.

5.2 INTERNALS, HORIZONTAL:

- Floor: Carpet. Maximum pile thickness of 1/2". Edges fastened to floor surface and edge trim beveled with slope no greater than 1:2.
- Ceiling: Suspended, exposed grid, lay-in acoustical tile.

5.3 FINISHES, SPECIAL:

- None.

5.4 INTERIORS:

- None.

6.0 SPECIALTIES:

- None.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None.

10.1 PLUMBING AND FIRE PROTECTION:

- No Plumbing.
- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilation (no A/C) at NAU Flagstaff.

11.0 ELECTRICAL:

- Lighting: Fluorescent fixtures, ceiling, recessed.
- Power: AC power outlets each wall.
- Special Systems - Audio, video, computer jacks: 2 dual jacks (data and voice), 1 jack coaxial broadband.
- Class A Fire Alarm System, audible and visible.

B-311 OFFICE (150 + S.F.)

Wheelchair accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls floor to structure, STC 45 minimum.
- Door and frame, hollow metal.

5.2 INTERNALS, HORIZONTAL:

- Floor: Carpet. Maximum pile thickness of 1/2". Edges fastened to floor surface and edge trim beveled with slope no greater than 1:2.
- Ceiling: Suspended, exposed grid, lay-in acoustical tile.

5.3 FINISHES, SPECIAL:

- None.

5.4 INTERIORS:

- None.

6.0 SPECIALTIES:

- None.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None.

10.1 PLUMBING AND FIRE PROTECTION:

- No Plumbing.
- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilation (no A/C) at NAU Flagstaff.

11.0 ELECTRICAL:

- Lighting: Fluorescent fixtures, ceiling, recessed.
- Power: AC power outlets each wall.
- Special Systems - Audio, video, computer jacks: 2 dual jacks (data and voice), 2 jacks coaxial broadband.
- Class A Fire Alarm System, audible and visible.

B-350 CONFERENCE ROOM (TO 25), 500 S.F.

Wheelchair accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls floor to structure, STC 45 minimum.
- Door and frame, hollow metal with sound control, gasketed STC 45 minimum.

5.2 INTERNALS, HORIZONTAL:

- Floor: Carpet. Maximum pile thickness of 1/2". Edges fastened to floor surface and edge trim beveled with slope no greater than 1:2.
- Ceiling: Suspended, exposed grid, lay-in acoustical tile.

5.3 FINISHES, SPECIAL:

- None.

5.4 INTERIORS:

- None.

6.0 SPECIALTIES:

- Chalk/marker board.
- Projection screen.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None.

10.1 PLUMBING AND FIRE PROTECTION:

- No Plumbing.
- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilation (no A/C) at NAU Flagstaff.

11.0 ELECTRICAL:

- Lighting: Fluorescent fixtures, ceiling, recessed. (Two zone switching - lighting foot candles can be reduced for presentations).
- Power: AC power outlets each wall.
- Special Systems - Audio, video, computer jacks: 2 dual jacks (data and voice), 1 jack coaxial broadband.
- Central location for control of lights and media.
- Class A Fire Alarm System, audible and visible.

B-351 CONFERENCE ROOM (ADVANCED T.V.), 600 S.F.

Wheelchair accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls floor to structure, STC 45 minimum.
- Door and frame, hollow metal with sound control, gasketed STC 45 minimum.

5.2 INTERNALS, HORIZONTAL:

- Floor: Carpet. Maximum pile thickness of 1/2". Edges fastened to floor surface and edge trim beveled with slope no greater than 1:2.
- Ceiling: Suspended, exposed grid, lay-in acoustical tile.

5.3 FINISHES, SPECIAL:

- None.

5.4 INTERIORS:

- None.

6.0 SPECIALTIES:

- Chalk/marker board.
- Projection screen.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None.

10.1 PLUMBING AND FIRE PROTECTION:

- No Plumbing.
- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilation (no A/C) at NAU Flagstaff.

11.0 ELECTRICAL:

- Lighting: Fluorescent fixtures, ceiling, recessed. (Two zone switching - lighting foot candles can be reduced for presentations).
- Power: AC power outlets each wall.
- Special Systems - Audio, video, computer jacks: 2 dual jacks (data and voice), 1 jack coaxial broadband.
- Provisions for video to video transmittal.
- Central location for control of lights and media.
- Class A Fire Alarm System, audible and visible.

B-360 OPEN OFFICE AREA W/MODULAR WORK STATIONS (100 S.F. PER STATION)

Wheelchair accessible.

- 5.1 INTERNALS, VERTICAL:
 - Perimeter walls floor to structure, STC 45 minimum.
 - Door and frame, hollow metal.
- 5.2 INTERNALS, HORIZONTAL:
 - Floor: Carpet. Maximum pile thickness of 1/2". Edges fastened to floor surface and edge trim beveled with slope no greater than 1:2.
 - Ceiling: Suspended, exposed grid, lay-in acoustical tile.
- 5.3 FINISHES, SPECIAL:
 - None.
- 5.4 INTERIORS:
 - None.
- 6.0 SPECIALTIES:
 - None.
- 7.0 EQUIPMENT:
 - None.
- 8.0 SPECIAL CONSTRUCTION:
 - None.
- 10.1 PLUMBING AND FIRE PROTECTION:
 - No Plumbing.
 - Sprinkler system.
- 10.2 HVAC:
 - Heating and air conditioning.
 - Heating and ventilation (no A/C) at NAU Flagstaff.
- 11.0 ELECTRICAL:
 - Lighting: Fluorescent fixtures, ceiling, recessed.
 - Power: AC power outlets each wall and in each station by power poles.
 - Special Systems - Audio, video, computer jacks (fed by power poles): 1 dual jack (data and voice) at each station, 1 jack coaxial broadband at each station.
 - Class A Fire Alarm System, audible and visible.