

B-WWW CIRCULATION

Wheelchair accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls, floor to structure, of metal studs and gypsum board. Fire rating required depending on occupancy.
- Doors and frames, hollow metal.

5.2 INTERNALS, HORIZONTAL:

- Floor: Vinyl composition tile. Carpet; max pile thickness 1/2". Edges fastened to floor surface and edge trim beveled with slope no greater than 1:2.
- Ceiling: Suspended, exposed grid, lay-in acoustical tile.

5.3 FINISHES, SPECIAL:

- None

5.4 INTERIORS:

- None.

6.0 SPECIALTIES:

- Tack boards/depending on circulation location and width.
- Signage: Raised and brailled and pictorial symbol signs.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None

10.1 PLUMBING & FIRE PROTECTION:

- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilating (No A/C) at NAU Flagstaff.

11.0 ELECTRICAL:

- Lighting Fluorescent fixtures, ceiling, recessed.
- Power - A.C. outlets.
- Class A Fire Alarm System, audible and visible.

B-XXX CUSTODIAL

Individuals with disabilities can approach, enter and exit, but work areas are not required to be accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls, floor to structure, of metal studs and gypsum board.

5.2 INTERNALS, HORIZONTAL:

- Floor: Vinyl composition tile, sealed concrete.
- Ceiling: Suspended, exposed grid, lay-in acoustical tile, on exposed structure.

5.3 FINISHES, SPECIAL:

- Epoxy wall finishes or water resistant panels at mop sink area.

5.4 INTERIORS:

- Minimal length of base and wall cabinets.

6.0 SPECIALTIES:

- Tack board.
- Mop rack.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None.

10.1 PLUMBING & FIRE PROTECTION:

- Water, drain.
- Mop sink.
- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilating (No A/C) at NAU Flagstaff.

11.0 ELECTRICAL:

- Lighting Fluorescent fixtures, ceiling, recessed.
- Power - A.C. outlets.
- Class A Fire Alarm System, audible and visible.

B-YYY MECHANICAL/ELECTRICAL

Individuals with disabilities can approach, enter and exit, but work areas are not required to be accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls, floor to structure, fire rated, STC 58-65 minimum.
- Doors and frames: Fire rated and gasketed sound control.

5.2 INTERNALS, HORIZONTAL:

- Floor: Sealed concrete.
- Ceiling: Exposed structure or suspended acoustical tile to provide fire rating as required.

5.3 FINISHES, SPECIAL:

- Plywood panel for telephone board.

5.4 INTERIORS:

- None.

6.0 SPECIALTIES:

- None.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None.

10.1 PLUMBING & FIRE PROTECTION:

- Water, drain.
- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilating (No A/C) at NAU Flagstaff.
- Additional and/or specialized air handling depending on equipment in room.

11.0 ELECTRICAL:

- Lighting Fluorescent fixtures, ceiling, recessed or suspended.
- Power - A.C. outlets and/or as required for equipment.
- Class A Fire Alarm System, audible and visible.

B-ZZZ PUBLIC TOILET ROOMS

Wheelchair accessible.

5.1 INTERNALS, VERTICAL:

- Perimeter walls, floor to structure, on metal studs and gypsum board, epoxy paint.
- Doors and frames, hollow metal.

5.2 INTERNALS, HORIZONTAL:

- Floor: Ceramic, quarry tile.
- Ceiling: Suspended gypsum board ceiling painted.

5.3 FINISHES, SPECIAL:

- Ceramic tile walls.

5.4 INTERIORS:

- None.

6.0 SPECIALTIES:

- Toilet partitions.
- Mirrors: stainless steel shelves, soap dispensers, paper towel dispenses and receptacle, sanitary napkin dispenses and receptacle, toilet paper holder, grab bars.

7.0 EQUIPMENT:

- None.

8.0 SPECIAL CONSTRUCTION:

- None.

10.1 PLUMBING & FIRE PROTECTION:

- Water, drains.
- Water closets, lavatories, urinals.
- Sprinkler system.

10.2 HVAC:

- Heating and air conditioning.
- Heating and ventilating (No A/C) at NAU Flagstaff.
- Exhaust.

11.0 ELECTRICAL:

- Lighting Fluorescent fixtures, ceiling, recessed.
- Power - A.C. outlets.
- Class A Fire Alarm System, audible and visible.